



Addendum #1 – August 3, 2022

RFP 2223-01 – Generator & Installation – Fort Lawn Fire Department

Questions and Answers:

Q: What is the voltage requirement?

A: 240

Q: Single Phase or Three Phase power?

A: Single

Q: Are there any sound restrictions that we need to make the generator abide by?

A: No

Q: How many output breakers do you need on the generator?

A: One

Q: Will the transfer switch be inside or outside?

A: Outside

Q: What is the performance period for this contract?

A: As soon as possible.

Q: What are the automatic transfer switch voltage requirements?

A: 120/240

Q: Is this generator going to sit in the open or be covered?

A: In the open.

Q: Is the concrete pad required just to support the generator?

A: The concrete pad will support the generator.

Q: Is there an engineering estimated budget?

A: No